

NOTES:

CONCRETE SHALL BE CLASS AA, 4000 PSI AS PER ASTM C-478.


STEEL REINFORCING SHALL MEET ASTM C-185 (4" DIA) OR ASTM C-478 (5" DIA).

MANHOLES OVER 3'-6" IN DEPTH SHALL BE PROVIDED WITH STEPS 16" ON CENTERS. STEPS SHALL BE IN ACCORDANCE WITH COG STD. #206.

ON NEW INSTALLATION A MAXIMUM OF (2) GRADE RINGS CAN BE USED.

FOR FORCE MAINS LESS THAN 8" IN DIAMETER USE ROCKWELL SERVICE SADDLE 323, FORD, MUELLER, OR EQUAL.

ALL PIPE TO BE MINIMUM 2" BRASS AND NIPPLES TO BE 2" BRASS.



SECTION THRU MANHOLE

C I T Y O F G R E E N S B O R O

**STANDARD AIR RELIEF VALVE WITH ASSEMBLY
AND MANHOLE FOR SANITARY SEWER LINES**

STD. NO.

211

REV.

06-99
08-02
09-02